



Please note that upon license renewal of medical facilities the following ARCHITECTURAL points should be inspected:

1. Wash basin in each consultation room
2. Wash basin in treatment rooms
3. Sterilization room in dental facilities with wash basin(separate access)
4. Handicapped toilet(choose one toilet)
5. Dirt utility room with separate access.
6. Clean utility room with separate access
7. Size of consultation room should not be less than 12 sqm if containing an examination bed and,9 sqm if without an examination bed.
8. Minimum width for consultation room 3m.
9. Minimum width for treatment room 2 m.
10. Minimum area for treatment room is 7.5 sqm.
11. Corridor width not less than 120 cm.
12. Gynecology consultation room should have private access to toilet.

المعايير المطلوبة لتجديد المنشآت الصحية في وزارة الصحة ووقاية المجتمع:

- توفير مغاسل في غرف الاستشارة.
- توفير مغاسل في غرف العلاج والكشف.
- توفير غرفة للتعقيم في عيادات ومراكز الاسنان مع توفير مغسلة فيها (يكون لها مدخل خاص).
- فرش احدى الحمامات المتوفرة لذوي الاحتياجات الخاصة.
- توفير غرفة للنفايات الطبية (يكون لها مدخل خاص).
- توفير غرفة للادوات النظيفة (يكون لها مدخل خاص).
- اقل مساحة لغرف الاستشارة لا تقل عن 12 متر مربع (مع سرير الكشف) ، 9 متر مربع (بدون سرير الكشف).
- اقل عرض لغرف الاستشارة لا تقل عن 3 أمتار .
- اقل عرض لغرف الكشف والعلاج لا تقل عن مترين .
- اقل مساحة لغرف الكشف والعلاج لا تقل عن 7.5 منر مربع.
- الممر العام للمنشأة الصحية يجب ان لا يقل عن 120 سم.
- يجب توفير حمام في داخل غرف العيادات النسائية.